

Fellestraadet for Det Soerlige Afrika
c/o Royal Norwegian Embassy
P.O. Box 9012
Dar es Salaam

ATT : MR.K.MEKKI

NPA-DSM.
J. No: 380
DATE 9.5.88
Main Office:
Bygdøy Allé 5
0257 Oslo 2, Norway
Tel.: (02) 56 56 90/5
International call: +47 2 56 56 90/5
Telex: 19361 Nplan N

Your ref.:

Our ref.: T024/NT166/88/CWG/jm

DSM.88.05.09

RE : T024. SUPERVISION OF ANC HOUSE AT KURASINI PLOT 28

REPORT OF SITE VISITS ON 3/5-88 AND 6/5-88

3/5-88


1. Hardcoring under slab proceeding satisfactorily except some stones are very big and must be broken. Hand rammer on site but no mechanical compactor.
2. Excavation of septic tank nearly completed but with difficulty due to collapsing sides.
3. No apparent work going on in old units 1 and 2.

6/5-88

1. Hardcoring under slab generally completed but fill with smaller stones and blinding yet to be done.
2. Septic tank base slab, external blockwork completed.
Internal plastering in progress.
Soak pit excavation in progress.
3. No appreciable work in old units 1 and 2.
4. Aggregate(coarse) being washed in preperation for floor slab concrete.
5. No coarse sand on site yet for floor slab concrete.
6. Gate House
 - a) External roofing timbers and under side of roof tiles to be cleaned where dirtied by tyrolean render.
 - b) Down pipe(plastic)from cistern to toilet basin to be protected with brackets or surround of timber.
 - c) Wall around water supply pipe to toilet cistern to be made good and painted again.
 - d) Water system remains to be tested.

...Cont'd 2/..

Yours faithfully,
for NORPLAN A/S (T) BRANCH



C.W. GOMES
Projects Engineer.

NORPLAN
TANZANIA BRANC.
P.O. BOX 2820
DAR ES SALAAM
TANZANIA

c.c Mr. K. Ekeberg , NORPLAN Oslo.